

West Knox Utility Annual Drinking Water Report for 2006

West Knox Utility District is pleased to present this year's Annual Water Quality Report. The information contained in the table covers the period from January 1, 2006 through December 31, 2006. This report shows that your drinking water, like all drinking water (including bottled water) contains small amounts of contaminants. It is important to remember that the presence of these contaminants does not necessarily pose a health risk. The United States Environmental Protection Agency (EPA) and the Tennessee Department of Health and Conservation (TDH&C) have established limits on these contaminants and have determined that your drinking water provided by West Knox Utility District is safe to drink.

Presently West Knox Utility District operates two surface water treatment plants both located on the Clinch River on Melton Hill Lake. Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water source to **potential** contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving this water system. The SWAP report assesses the susceptibility of untreated water sources to **potential** contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible (high), moderately susceptible (moderate) or slightly susceptible (low), based on geologic factors and human activities in the vicinity of the water source. The WKUD Water System sources are rated as reasonably susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at www.state.tn.us/environment.dws.dwassess.shtml or you may contact the Water System to obtain copies of specific assessments.

As you can see by the table our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The EPA has determined that your water **IS SAFE** at these levels.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek the advise about drinking water from their health care providers. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Hotline at 1-800-426-4791.

We want all of our customers to be informed about their water and utility. If you want to learn more please attend any of our regularly scheduled meetings. They are held on the 4th Thursday of each month at 9:00 a.m. at the West Knox Utility District office located at 2328 Lovell Road, Knoxville, Tennessee. You may also contact West Knox Utility District as listed below:



P.O. Box 51370
Knoxville, TN 37950-1370

Phone: 865-690-2521

Fax: 865-531-1960

Email: www.wkud.com

Water Quality Report 2006



West Knox Utility District

Terms & Definitions

Below Detectable Limits (BDL) - Laboratory analysis indicates that the contaminant is not present in a detectable quantity.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one minute in two years of a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter- one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/L) - one part per trillion corresponds to one minute in 2,000,000 years or one penny in \$10,000,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/L) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L)- picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr)- measure of radiation absorbed by the body.

Million Fibers per Liter (MFL)- million fibers per liter is a measure of the asbestos fibers that are no longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU)- nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity does not present any risk to your health. West Knox Utility District monitors turbidity because it is a good indicator that our filtration system is functioning properly.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions. The State of Tennessee does not allow variations and exemptions.

Action Level- The concentration of a containment, which, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL)- The "maximum allowed" is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum Containment Level Goal (MCLG)- The goal is the level of contaminant in drinking water, which below there is no known or expected risk to health. MCLG's allow for a margin of safety.

CCR Units- CCR Units express the MCL in whole numbers. For example ppb are used to eliminate fractions of ppm. (I.E. 0.050 ppm = 50 ppb)

MRDL- 'Maximum Residential Disinfectant Level'- the highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.

MRDLG- 'Maximum Residential Disinfectant Level Goal'- The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Water Quality Summary

Contaminant	MCLG	MCL	Level Found	Range of Detections	Violations	Sample Date	Typical Source of Contaminant
Total Coliform Bacteria	0	N/A	0	N/A	N	50/month	Naturally Present In The Environment
Fecal Coliform & E. Coli	0	N/A	0	N/A	N	50/month	Human & animal fecal waste
Turbidity	N/A	TT 95% < 0.3 NTU	0.16 Plant A 0.12 Plant B	0.03-0.16 Plant A 0.05-0.12 Plant B	N	Continuous	Soil Run-Off
Sodium	N/A	N/A	12 ppm 11 ppm	12 ppm Plant A 11 ppm Plant B	N	2-08-06	Erosion of Natural Deposits
Sulfate	N/A	250 ppm	20 ppm 20 ppm	20 ppm Plant A 20 ppm Plant B	N	9/12/05	Erosion Of Natural Deposits
Barium	2	2 ppm	0.035 ppm 0.035 ppm	0.035 Plant A 0.035 Plant B	N	9/12/2005	Discharge of Drilling Wastes; Discharge from metal refineries.
Iron	N/A	N/A	BDL	BDL	N	9/12/2005	Erosion of Natural Deposits
Copper (0 out of 30 sites exceeded Cu action level)	1.3	AL=1.3 ppm	90th Percentile = 0.026 ppm	0.028-0.081 ppm	N	June 2005	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.
Flouride Plant A Plant B	4 4	4 ppm 4ppm	1.05 ppm 1.03 ppm	0.02- 1.36 ppm 0.00- 1.28ppm	N N	Daily	Erosion of Natural Deposits; Water additive which promotes strong teeth; Discharge from fertilizer & aluminum factories.
Lead (0 out of 30 sites exceeded Pb action level)	0	AL=15 ppb	90th Percentile = 2.8 ppb	1.0 ppb-5.0 ppb	N	June 2005	Corrosion of household systems.
Nitrate	10 10	10 ppm 10 ppm	BDL Plant A ppm 0.31 Plant B ppm	BDL Plant A ppm 0.31 Plant B ppm	N N	7/12/06	Run-off from fertilizer use;
ITHM's (Total Trihalomethanes)	0 0	80 ppb 80 ppb	46 Plant A ppb 39 Plant B ppb	23-81 ppb Plant A 17-54 ppb Plant B	N N	Quarterly	Byproduct of Drinking Water Chlorination.
HAA5's (Total Haloacetic Acids)	0 0	60 ppb 60 ppb	36 Plant A ppb 28 Plant B ppb	15-55 ppb Plant A 10-43 ppb Plant B	N N	Quarterly	Byproduct of Drinking Water Chlorination
TOC's Total Organic Carbon (WKUD met the treatment technique for Total Organic Carbon)	0 0	TT TT	1.39 Plant A ppm 1.15 Plant B ppm	1.20-1.70 ppm .56-1.40 ppm	N N	Monthly	Naturally present in the environment.
Chlorine Plant A Plant B	MRDL <4 <4	MRDLG 4 4	2.52 ppm Ave. 2.52 ppm Ave.	2.28- 2.66 ppm 2.28-2.66 ppm	N N	Continues	Disinfection